

# 試驗報告



報告編號：HB-17-09695

C-17-33421

頁數：1 OF 1

報告日期：107年01月04日

工程名稱：國產建材實業台北港大陸砂氣離子例行性檢驗  
 委託單位：國產建材實業股份有限公司  
 樣品名稱：大陸砂  
 結構部位：砂石船邊取樣  
 加註項目：匯順輪 V1782(青州)  
 取樣人員：國產建材實業股份有限公司(呂昭智)、國產建材實業股份有限公司購料處港務課(張耀聰)  
 送驗人員：國產建材實業股份有限公司(魏斌輝)  
 取樣日期：106年12月25日  
 收件日期：106年12月28日  
 試驗日期：107年01月02日~107年01月04日  
 備註：1. 以上資料由顧客提供(收件及試驗日期除外)  
       2. 除非另有說明，此報告結果僅對測試之樣品負責  
       未經本公司事先書面同意，此報告不可部分複製  
       3. 送樣方式為實驗室收件

=====  
 試驗結果：

試驗項目	試驗方法	試驗結果
水溶性氯離子含量(%)	CNS 13407(2015)	0.0006

規範要求值僅供參考，合格之判定以委託單位實際要求為準。

張正德  
 報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.